

# Efficient Product Rebates

## Commercial Heating Rebate Guide

The following tables list product requirements and available rebates for a range of energy-efficient commercial heating equipment. If you are looking for Variable Frequency Drive (VFD) rebates for HVAC equipment please see the Commercial VFD Rebate Guide. For more information please visit our website [efficiencyns.ca/business](http://efficiencyns.ca/business).

If your utility bill is less than \$3,800 monthly and you have not yet purchased your products, your business may qualify for rebates in addition to those listed here.

### Integrated Dual Enthalpy Economizer Controls

Product	Requirements	Rebate
Integrated Dual Enthalpy Economizer Controls	<ul style="list-style-type: none"> <li>Must be installed on new equipment that is also eligible for rebates</li> </ul>	\$250

### HVAC Hotel Occupancy Sensors

Product	Requirements	Rebate
With building integrated intelligent control	<ul style="list-style-type: none"> <li>Must control electric heating*</li> <li>Maximum of one rebate per room</li> </ul>	\$75
Without building integrated intelligent control	<ul style="list-style-type: none"> <li>Must set back temperature when space is not occupied</li> <li>Hotel must operate year round</li> </ul>	\$50

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the occupancy sensor may control any heat source.

### Small Air Source Heat Pumps - Installed in Multi-Unit Facilities (3 or more units)

Size (Nominal Capacity)	Type	Min HSPF (Region IV)	Min SEER	Requirements	Rebate
< 65,000 Btu/h (< 5.4 tons)	Ductless Mini-Split Heat Pump	11	17	<ul style="list-style-type: none"> <li>Applicant must be property owner</li> <li>Property must have three units or more and be electrically heated*</li> <li>Ductless Mini-Split Heat Pump rebates limited to a maximum of 40 units per facility</li> <li>Heat pump must be utilized over the heating season</li> <li>Systems must be AHRI matched systems</li> <li>Contact us prior to purchase if replacing an existing air-source heat pump or in new construction</li> </ul>	\$400 / ton
	Multi-Zone	10	15		

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the property is not required to be electrically heated.

## Small Air Source Heat Pumps - Installed in Commercial Facilities

Size (Nominal Capacity)	Type	Min HSPF (Region IV)	Min SEER	Requirements	Rebate
< 65,000 Btu/h (< 5.4 tons)	Single Package Systems	8.2	15	<ul style="list-style-type: none"> <li>Facility must be commercial property</li> <li>Heat Pump must be utilized over the heating season</li> <li>Must offset electric resistance heating*</li> <li>Systems must be AHRI matched systems</li> <li>Contact us prior to purchase if replacing an existing air-source heat pump or in new construction</li> </ul>	\$500 / ton
	Centrally Ducted Split System Heat Pump	8.5	15		\$600 / ton
	Ductless Mini-Split Heat Pump	11	17		\$500 / ton
		12	22		\$600 / ton
	Multi-Zone	10	15		\$400 / ton

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the heat pump is not required to offset electric resistance heating.

## Large Air Source Heat Pumps

Single package (unitary) systems, ducted split systems, and ductless split systems.

Size (Nominal Capacity)	High Heating (47F) Min COP	Low Heating (17F) Min COP	Min EER	Requirements	Rebate
≥ 65,000 Btu/h and < 135,000 Btu/h	3.4	2.25	11	<ul style="list-style-type: none"> <li>Heat pump must be utilized during heating season</li> <li>Must offset electric resistance heating*</li> </ul>	\$600 / ton
	3.6	2.45	11.9		\$700 / ton
≥ 135,000 Btu/h and < 240,000 Btu/h	3.2	2.05	10.4	<ul style="list-style-type: none"> <li>Systems must be AHRI certified matched systems. More information at <a href="http://ahridirectory.org">ahridirectory.org</a></li> </ul>	\$600 / ton
	3.5	2.25	11.4		\$700 / ton

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the heat pump is not required to offset electric resistance heating.

## Ground & Water Source Heat Pumps

Size (Nominal Capacity)	Min EER	Min COP	Requirements	Rebate
Open Loop	16.2	3.6	<ul style="list-style-type: none"> <li>Heat pump must be utilized during heating season</li> <li>Must offset electric resistance heating*</li> <li>Systems must be AHRI certified matched systems. More information at <a href="http://ahridirectory.org">ahridirectory.org</a></li> </ul>	\$500 / ton
	20.0	4.0		\$600 / ton
Closed Loop / Direct Geoexchange (DGX)	13.4	3.1	<ul style="list-style-type: none"> <li>Contact us if replacing an existing air-source or water source heat pump or in a new construction</li> <li>Water loop heat pumps connected to a cooling tower and boiler are not eligible for incentives</li> <li>Tested in accordance to ASHRAE / ANSI / AHRI / ISO standard 13256-1 &amp; 2:2012</li> </ul>	\$500 / ton
	16.0	3.6		\$600 / ton

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the heat pump is not required to offset electric resistance heating.

## Air-to-Water Heat Pumps

Size (Nominal Capacity)	COP <sub>H</sub> at -15°C	Requirements	Rebate
≤ 135,000 Btu/h	1.7	<ul style="list-style-type: none"> <li>Heat pump must be utilized during the heating season</li> <li>Must offset electrical resistance heating* (not for SBES-NE)</li> <li>Products must be CSA approved for use in Canada</li> <li>Other hydronic systems (excluding in-floor radiant) must include additional heat exchangers and/or a heat load calculation confirming the baseline equipment is sufficient at indoor loop operating temp</li> <li>Split units must be designed for use together</li> <li>Minimum 110F Water Supply Temperature</li> <li>Contact us if replacing an existing air-source or water source heat pump or in new construction</li> </ul>	\$500 / ton

\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the heat pump is not required to offset electric resistance heating.

## Packaged Terminal Heat Pumps (PTHP)

Size (Nominal Capacity)	New Construction (Standard Size*)		Replacement (Non-Standard Size**)		Requirements	Rebate
	High Heating (47F) Min EER	Low Heating (17F) Min COP	Min EER	Min COP		
< 11,000 Btu/h	11.0	3.3	9.3	2.7	<ul style="list-style-type: none"> <li>Heat pump must be utilized during heating season</li> <li>Must offset electric resistance heating***</li> </ul>	\$500 / per unit
≥ 11,000 Btu/h	10.0	2.8	7.6	2.5	<ul style="list-style-type: none"> <li>Must be AHRI certified (standard size only)</li> <li>Contact us if replacing an existing PTHP unit or in a new construction</li> </ul>	

\*Standard size refers to having an external wall opening greater than or equal to 16 inches high or greater than or equal to 42 inches wide, and a cross-sectional area greater than or equal to 670 square inches.

\*\*Non-standard size refers to having an external wall opening of less than 16 inches high or less than 42 inches wide, and a cross-sectional area less than 670 square inches.

\*\*\*If your utility bill is less than \$3,800 per month and you have not yet purchased your product, the heat pump is not required to offset electric resistance heating.

## Commercial Electric Thermal Storage (ETS) Systems

Product	Requirements	Rebate
Small Commercial ETS: 50 - 150 kWh of Eight-Hour Storage	<ul style="list-style-type: none"> <li>\$20 per kWh, lesser of total storage or eight hour storage amount (charging power multiplied by eight)</li> </ul>	\$1,000 / per unit
Medium Commercial ETS: 150 - 300 kWh of Eight-Hour Storage	<ul style="list-style-type: none"> <li>Must be supplementing electric heat source</li> </ul>	\$2,000 / per unit
Large Commercial ETS: 300 kWh and above of Eight-Hour Storage	<ul style="list-style-type: none"> <li>Contact us if the ETS unit(s) will be installed in a New Construction</li> </ul>	\$4,000 / per unit